

August 20, 2024

DEDHAM-WESTWOOD WATER DISTRICT
DEDHAM, MASSACHUSETTS

DOCUMENTS AND SPECIFICATIONS FOR THE

WHITE LODGE WATER TREATMENT PLANT
AERATION TOWER MEDIA REPLACEMENT

CONTRACT NO. 4

ADDENDUM NO. 2



The following additions and/or alterations to the plans and specifications for the above-referenced contract are to be incorporated into all general bids for the proposed work.

Inclusion of this Addendum must be acknowledged by inserting the addendum number and date in The Form for General Bid, page 00300-1 of the specifications. The Addendum must also be acknowledged in the Contract Agreement, Article 7, paragraph 7.01.12, page 00510-3 of the specifications upon execution of the Contract Agreement. Failure to acknowledge any and all addenda in the Form for General Bid may be cause for rejection of the bid by the OWNER on the grounds that it is not responsive to the "INFORMATION FOR BIDDERS."

The following are responses to questions received:

1. Q: Has the material to be disposed of been tested for PFAS? If so, can you please provide most recent testing results.
A: No, the media inside the aeration towers has not been tested for PFAS.
2. Q: If PFAS has not been tested for, is it considered a contaminant of concern?
A: To our knowledge, PFAS is not removed in the aeration process nor should the manganese that is on the media remove PFAS from the raw water. The Contractor should confirm all testing requirements with the chosen landfill to be used for disposing of the solid waste. This cost shall be included under Bid Item No. 2 as described in Section 01025 - Measurement & Payment.

END OF ADDENDUM NO. 2